

PASTEUR INSTITUTE OF INDIA
COONOOR - 643 103 (NILGIRIS)

CORRIGENDUM

Date: 23/12/2020

**DUE DATES FOR SUBMISSION OF TECHNICAL & FINANCIAL BID IN RESPECT OF TENDER
No: PII/ADVT/004/2020 dated on 10/12/2020**

| Sl. No | Description | Schedule |
|---------------|---|-------------------------------------|
| 1. | Closing date & time for receipt of tender | 31/12/2020, 15.00 Hrs |
| 2. | Time and date of opening of tender | 31/12/2020, 15.30 Hrs |
| 3. | Venue of opening of tender | PASTEUR INSTITUTE OF INDIA, COONOOR |

Minutes of the Pre-Bid Conference Meeting

The Pre Bid Meeting as per the tender document with respect to Supply, Installation, Testing and Commissioning of IP based CCTV Surveillance system , Access Control Systems, backup system and Comprehensive Annual Maintenance for 03 years at PIIC was held at 12.00 hrs on 18.12.2020 in the Conference Hall of the Institute. The following members were present from official and vendor side.

On behalf of Pasteur Institute of India, Coonoor, Director welcomed all the vendors and the vendors have introduced themselves.

Below listed are the queries raised by different vendors attend in the pre bid meeting as well as by E- mail and clarification issued by PIIC for each query. The bidders are instructed to note the same and informed that no separate corrigendum will be issued in this regard.

PASTEUR INSTITUTE OF INDIA
COONOOR - 643 103 (NILGIRIS)

1. In pg.no 6, point d “Experience of having successfully completed one single order of the Supply, installation & Commissioning of clean room and non-clean room IP based CCTV systems, Access Control systems and their backup systems and Comprehensive Annual Maintenance Contract for 3 years at any Pharma / Vaccine company or other company during last 2 years in which tenders are invited for value not less than Rs.50 Lakhs. Copy of work order along with completion certificate to be submitted with technical bid”. The vendor asked shall we submit the PO as 40 Lakhs for CCTV and 10 Lakhs for Access Control.

PIIC clarification: Experience of having successfully completed one single order of the Supply, installation & Commissioning of clean room and non-clean room IP based CCTV systems, Access Control systems and their backup systems and Comprehensive Annual Maintenance Contract for 3 years at any Pharma / Vaccine company or other company during last 2 years in which tenders are invited for value not less than Rs.Fifty Lakhs (Total combined value for CCTV and Access Control). Copy of work order along with completion certificate to be submitted with technical bid

2. **Kindly consider 3 streams instead of 4 streams in camera specification.**

PIIC clarification: There is no Change in the tender specification PIIC retains the same as it is.

3. **NVR Bandwidth**

PIIC clarification: This point shall be changed to Minimum Incoming bandwidth 400 Mbps and Minimum Outgoing Bandwidth 400 Mbps.

4. In pg no 8, point a of general instruction “Due to security reasons, no China based Original Equipment Manufacturer (OEM) or Chinese organizations registered in anywhere are not allowed to participate in this tender. Declaration for the same on OEM letterhead should be submitted”. The vendor request to allow Make in India OEM's to participate in the tender even though the origin is China but we have Manufacturing plant in India and we can give Make in India certificate also you can verify by Indian BIS Certificate for the products we are quoting.

PIIC clarification: There is no Change in the tender specification PIIC retains the same as it is.

PASTEUR INSTITUTE OF INDIA
COONOOR - 643 103 (NILGIRIS)

5. In Pg no 17, point j “The NVR will be installed in the Command & Control Room and Alerts on detection of a blacklisted person should be displayed as an Alert on the NVR Screen” and vendor asked kindly remove this point. Since, it comes for facial reorganization.

PIIC clarification: This point shall be treated as removed in the tender document.

6. In Page No: 51, Sl.No 35. “Progressive scan, 8.0 megapixel, ANPR” and vendor requested to change the 8Mp Full HD Bullet Day/Night camera for Automatic Number Plate Recognition (ANPR to 2 Mp ANPR. To Capture Number plate from Vehicle, we need 50 FPS or more. In 8MP camera will not support 50 fps as a technology hurdle. Request to kindly amend 8MP camera and accept 2MP Full HD camera with 60 fps to capture the Vehicle number plate.

PIIC clarification: There is no Change in the tender specification PIIC retains the same as it is.

7. In Page No: 38, Sl.No 02“CE, FCC, UL, BIS, and KC certificate is only required for Korean made products” and the vendor asked is all the certification is necessary

PIIC clarification: This point shall be changed to BIS is Mandatory and any one of CE or FCC or UL or KC certification is required as applicable for the OEM.

8. For seamless operation all the Camera, NVR and software should be from same OEM”. The vendor request to change the Camera, NVR from same OEM and the VMS from different OEM or third party integration.

PIIC clarification: IP CCTV camera and NVR should be from same OEM and the VMS may be from third party. However, vendor has to ensure the seamless integration, operation and support. In case of any deviation from the technical specification given in the tender for VMS, the work order will be summarily cancelled at any time and the bank guarantee or security deposit shall be forfeit.

9. Storage Capacity shall be changed to 8x16 SATA along with 7200 RPM for HDD.

PIIC clarification: There is no Change in the tender specification PIIC retains the same as it is.

PASTEUR INSTITUTE OF INDIA
COONOOR - 643 103 (NILGIRIS)

10. Client Connection Gigabit Ethernet (Client) x1Video In Connection Gigabit Ethernet (Video-in) x2

PIIC clarification: This point shall be changed to Client Connection Gigabit Ethernet (Client) x1Video In Connection Gigabit Ethernet (Video-in) x1

11. ANPPR camera is a strategic product, where each OEM would follow different lens combination to achieve high accuracy. Request to kindly amend lens to 3.6 mm (±3) ~ 12 mm (±3) varifocal, AF automatic focusing and motorized zoom lens

PIIC clarification: There is no Change in the tender specification PIIC retains the same as it is.

12. Need to know whether we should submit MAC address details before product billing or after billing the products.

PIIC clarification: vendors have to submit the MAC address during the Installation and Commissioning of the project.

13. Both Traffic Count and Wrong way detection, is this mandatory we understand these feature are helpful to enforcement agencies unlike requirement of Education institute. With all other functions are In-built OCR in camera, it will also reduce the Separate ANPR License cost

PIIC clarification: There is no Change in the tender specification PIIC retains the same as it is.

14. For more accountable the OEM and Bidders shall follow the GFR 2017

PIIC clarification: PIIC will follow the GFR 2017.

15. The PIIC should call for demo of the Equipments if required during the Technical evaluation.

PIIC clarification: Kindly refer the page no 16 of the tender documents for demo related details.

16. Progressive scan, 5.0 megapixel, CMOS shall be changed to Progressive scan, 8.0 megapixel, CMOS”

PIIC clarification: There is no Change in the tender specification PIIC retains the same as it is.

PASTEUR INSTITUTE OF INDIA
COONOOR - 643 103 (NILGIRIS)

17. Trigger events, Trigger Events with suitable analytics, Data Security, Transmission Security.

PIIC clarification: Kindly refer the technical specification given in Appendix – A of the tender documents.

18. We suggest you to go with server based storage to save money for PIIC and you can add licenses only when you add a camera to the server in server based architecture.

PIIC clarification: There is no Change in the tender specification PIIC retains the same as it is.

19. We suggest you to go with industry standards such as 2 Megapixel and recording in 2 Megapixel to save money for PIIC, since this is the best practice done in the Industry

PIIC clarification: There is no Change in the tender specification PIIC retains the same as it is.

20. Indoor cameras are asked with IP67 rating which is not usable indoors we suggest a PVC free camera with IP56 since PIIC has clean rooms.

PIIC clarification: There is no Change in the tender specification PIIC retains the same as it is.

21. Percentage of Security Deposit should be provided after LOA

PIIC clarification: 3 percentage of the total work order value.

Sd/-
(Dr. S. Sivakumar)
Director.